



District Level Water Analysis Laboratory

OFFICE OF EXECUTIVE ENGINEER, KHAND KARYALAY
Uttar Pradesh Jal Nigam, (Rural) Fatehpur (212601)

TEST REPORT (WATER)

Report N C:	C/03/2026/5315	Date:	25/03/2026		
Customer details					
Office Name and Address:	A B International School Dehuli Fatehpur				
Ref Letter No & Date:	A.B.I.S./A.S./042 & 23/03/2026				
Basic details of sample					
District:	Fatehpur	Block:	BHITAURA		
Gram Panchayat / Town :	Dehuli	Village/ City:	Dehuli		
Habitation:	Dehuli	Location:	NH- 19 Tharion Fatehpur		
Water Source:	RO	Sample no:	5315		
Quantity of Sample:	2.0 Lit	Date of S.C.:	14/03/2026		
Receiving Date:	16/03/2026	S. Collector:	Renu Singh		
Sample Depositor:	Renu Singh				
Analysis Start Date:	23/03/2026	Analysis Completion Date:	23/03/2026		
Environmental Condition					
Temperature	25±3°C	Relative Humidity	50 ± 15 %		
Technical Date of Analysis					
Sr. No.	Analysed Parameters	Result	Specified Values as Per BIS 10500:2023		Ref. Method Of Analsis
			Acceptable Limit	Permissible Limit	
1	Calcium (Mg/L)	45	75	200	IS 3025 (Part 40): 2024
2	Chloride (Mg/L)	13	250	1000	IS 3025 (Part 32): 2024
3	Colour (Hazen)	02	5	15	IS 3025 (Part 4): 2021
4	Fluoride (Mg/L)	0.70	1	1.5	APHA 24 th Edition-4500- F Method C (Electrode Method) :2023
5	Iron (Mg/L)	0.1	1	1	APHA 24 th Edition-3500- Fe Method B (Phenanthroline Method):2023
6	Magnesium (Mg/L)	11	30	100	IS 3025 (Part 46): 2023
7	Nitrate (Mg/L)	18	45	No Relaxation	APHA 24 th Edition-4500- NO ₃ Method B (UV Screening Method):2023
8	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
9	pH@ 25.9°C	7.78	6.5	8.5	IS 3025 (Part 11): 2022 (Electrometric Method)
10	Sulphate (Mg/L)	48	200	600	APHA 24 th Edition-4500- SO ₄ Method E (Turbidimetric Method):2023
11	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 08): 2023
12	Total Dissolved Solids (Mg/L)	99	500	2000	IS 3025 (Part 16): 2023
13	Total Alkalinity (Mg/L)	152	200	600	IS 3025 (Part 23): 2023
14	Total Hardness (Mg/L)	114	200	600	IS 3025 (Part 21): 2009
15	Turbidity (NTU)	0.62	1	5	IS3025 (Part 10):2023
BDL- Below Detection limit, NT- Not Tested					
Note	<ol style="list-style-type: none"> 1. This certificate refers only to the particular sample (S) submitted for testing. 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory. 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements. 4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue. 5. Sample Collection was submitted by the Customer; It's only Tested in Laboratory. 6. The Result applies to the Sample as Received. 				
	Report Prepared by Anu Kumar	Report Analysis by Pradeep Kumar			
		Renu Singh Director		Authorized Signatory Sandeep Kumar	

End of Test Report A.B. International School
Dehuli-Fatehpur

ANNEXURE-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 473 / W-13 / 23

Date: 25-03-2026

This is to certified that an inspection team headed by Mr. **Sandeep Kumar**, chemist from **District Level water Analysis Laboratory, U.P. JAL NIGAM (RURAL), FATEHPUR** Inspected Water Sample From **A B International School Dehuli Fatehpur** on **25/03/2026** and The water Sample Was found to be safe for drinking All the Facilities for the student & staff members are well maintained and campus are as per the norms Suggested by the Central/State/UT Govt.

The above is valid for a period of **25/03/2026** to **24/09/2026**

Signature : Sandeep
Name: Sandeep Kumar
Designation : Lab- Incharge

AK
अधिशायी अभियन्ता
उ०प्र० जल निगम (ग्रामीण)
Signature with Seal: फतेहपुर
Name : Anurag Gautam
Designation : Executive Engineer

Name & Address of the Office /Department :

EXECUTIVE ENGINEER DIVISION OFFICE
U.P.Jal Ngam (Rural), Sadipur , Fatehpur-212601

Sparsh
Principal
A.B. International School
Dehuli-Fatehpur

Renu Singh
Director
A.B. International School
Dehuli-Fatehpur

To,

Name: **A B International School**
Address: **Dehuli Fatehpur**

(NAME & ADDRESS OF THE INSTITUTION)